

May 11, 2017

EN1822 European HEPA Test
LMS Technologies, Inc.

Test Type :	EN1822	Test Requested By:	Ideal living management
Test Number:	T051117A	Filter Mfgr:	
Flow Rate/Velocity:	60 fpm, 30 cm/s	Filter/Media ID # :	Filter #2
Test Aerosol:	KCl, Neutralized	Filter/Media Size:	13.5" x 16.25" x 1.5"
ΔP ("H₂O):	0.0850", 21.3 Pascals		

Size Rang(μm)	Initial Fractional Efficiency(%)
0.0030	100.000

